Appendix 2-1. MPCA Design Flow Determination Worksheet



Design Flow and Loading Determination Guidelines for Wastewater Treatment Plants

Water Quality


Wastewater Review and Guidance

Water/Wastewater Technical Review and Guidance/#5.20, February 2002

A. Dete	rmine peak hourly wet weather design flows (PHWWF)	Flow, mgd
1	Present peak hourly dry weather flow	30.7
2	Present peak hourly flow during high ground water period (no run off)	38.3
3	Present peak hourly dry weather flow	30.7
4	Present peak hourly infiltration	7.6
5	Present peak hourly dry weather flow during high ground water period and runoff at point of greatest distance between curves Y and Z	48.3
6	Present hourly flow during high ground water (no runoff) at same time of day as (5) measurement	36.7
7	Present peak hourly inflow	11.6
8	Present peak hourly inflow adjusted for a 5-year 1-hour rainfall event	41.8
9	Present peak hourly infiltration	7.6
10	Peak hourly infiltration cost effective to eliminate	0.0
11	Peak infiltration after rehabilitation	7.6
12	Present peak hourly adjusted inflow	41.8
13	Peak hourly inflow cost effective to eliminate	0.0
14	Peak hourly inflow after rehaibilitation	41.8
15	Population increase:	
16	Peak hourly flow from planned industrial increase	0.0
17	Estimated peak hourly flow from future unidentified industries	0.0
18	Peak hourly flow from other future increases	0.0
19	Peak hourly wet weather design flow [1+11+ sum(1418)]	80.1
B. Dete	rmine peak instantaneous wet weather design flow (PIWWF)	
20	Peak hourly wet weather design flow [same as (19)]	80.1
	Present peak hourly inflow adjusted for a 5-year 1-hour rainfall event [same as	
21	(8)]	41.8
22	Present peak inflow adjusted for a 25-year 1 hour rainfall event	63.7
23	Peak instantaneous wet weather design flow [20-21+22]	102 ^a

a. Use 107 mgd for conservatism and estimate of 2014 peak hour flow - see below









Water Quality

Wastewater Review and Guidance

Design Flow and Loading Determination Guidelines for Wastewater Treatment Plants

Water/Wastewater Technical Review and Guidance/#5.20, February 2002

2050

A. Determine peak hourly wet weather design flows (PHWWF)		Flow, mgd	
1	Present peak hourly dry weather flow	30.7	
2	Present peak hourly flow during high ground water period (no run off)	38.3	
3	Present peak hourly dry weather flow	30.7	
4	Present peak hourly infiltration	7.6	
5	Present peak hourly dry weather flow during high ground water period and runoff at point of greatest distance between curves Y and Z	48.3	
6	Present hourly flow during high ground water (no runoff) at same time of day as (5) measurement	36.7	
7	Present peak hourly inflow	11.6	
8	Present peak hourly inflow adjusted for a 5-year 1-hour rainfall event	41.8	
9	Present peak hourly infiltration	7.6	
10	Peak hourly infiltration cost effective to eliminate	0.0	
11	Peak infiltration after rehabilitation	7.6	
12	Present peak hourly adjusted inflow	41.8	
13	Peak hourly inflow cost effective to eliminate	0.0	
14	Peak hourly inflow after rehaibilitation	41.8	
15	Population increase: 14 mgd * MCES Peaking Factor of 2.0	28.0	
16	Peak hourly flow from planned industrial increase	0.0	
17	Estimated peak hourly flow from future unidentified industries	0.0	
18	Peak hourly flow from other future increases	0.0	
19	Peak hourly wet weather design flow [1+11+ sum(1418)]	108.1	
B. Deter	B. Determine peak instantaneous wet weather design flow (PIWWF)		
20	Peak hourly wet weather design flow [same as (19)]		
	Present peak hourly inflow adjusted for a 5-year 1-hour rainfall event [same as		
21	[8]		
22	Present peak inflow adjusted for a 25-year 1 hour rainfall event		
23	Peak instantaneous wet weather design flow, (Current PIWWF + 14 mgd*2.0)	135.0	

