

Well and Storage Capacity

Community	Total Capacity of Source (MGD)	Firm Capacity (MGD) *	Total Storage (MG)	Storage (MG)
Afton	Community does not have a municipal system			
Andover	15.8	12.5	3.0	2 - 1.5 SE, 1 - 1.5 SU
Anoka	9.7	7.5	2.4	3 - 2.4 SE
Apple Valley	31.1	25.9	13.2	4 - 11.2 SE, 1 - 2 SU
Arden Hills	Served by St. Paul Regional Water Services (wholesale)		1.5	2 - 1.5 SE
Bayport	2.5	1.58	1.05	2 - 1.05 SU
Baytown Twp.	Community does not have a municipal system			
Belle Plaine	3.3	1.9	1.3	2 - 0.8 SE, 1 - .5 SU
Belle Plaine Twp.	Community does not have a municipal system			
Benton Twp.	Community does not have a municipal system			
Bethel	Community does not have a municipal system			
Birchwood Village	Served by White Bear Lake (wholesale)			
Blaine	20.8	17.4	8.0	3 - 3 SE, 1 - 5 SU
Blakeley Twp.	Community does not have a municipal system			
Bloomington	62.9	52.3	30.0	3 - 6 SE, 4 - 24 SU
	Served by Minneapolis (wholesale)			
Brooklyn Center	16.8	14.6	3.0	3 - 3 SE

* Firm capacity is the well capacity of a community if the highest capacity well is out of service.

Fields left blank where information is not available.

Community	Total Capacity of Source (MGD)	Firm Capacity (MGD) *	Total Storage (MG)	Storage (MG)
Brooklyn Park	31.5	27.5	15.0	4 - 4 SE, 4 - 11 SU
Burnsville	34.7	30.5	18.6	3 - 9.8 SE, 2 - 8.8 SU
Camden Twp.	Community does not have a municipal system			
Carver	1.9	1.2	0.1	1 - 0.1 SE
Castle Rock Twp.	Community does not have a municipal system			
Cedar Lake Twp.	Community does not have a municipal system			
Centerville	1.9	0.8	0.5	1 - 0.5 SE
Champlin	9.2	6.7	3.3	2 - 1.0 SE, 1 - 1.3 SU
Chanhassen	14.1	12.6	3.6	2 - 1.7 SE, 1 - 1.7 SU
Chaska	12.0	9.4	3.6	3 - 3.3 SE, 1 - .03 SU
Circle Pines	3.1	1.4	0.5	1 - 0.5 SE
Coates	Community does not have a municipal system			
Cologne	2.1	0.4	0.6	2 - 0.6 SE
Columbia Heights	Served by Minneapolis (wholesale)		6.45	1 - 0.25 SE, 1 - 6.2 SU
Columbus	3.6	2.0	0.0075	1 - 1 .0075 Hydromatic tank
Coon Rapids	38.2	35.8	14.5	3 - 4 SE, 2 - 10.5 SU
Corcoran	Community does not have a municipal system			
Cottage Grove	17.5	12.8	7.2	4 - 3.1 SE, 2 - 4 SU

* Firm capacity is the well capacity of a community if the highest capacity well is out of service.

Fields left blank where information is not available.

Community	Total Capacity of Source (MGD)	Firm Capacity (MGD) *	Total Storage (MG)	Storage (MG)
Credit River Twp.	Community does not have a municipal system			
Crystal	Served by the Joint Water Commission			
Dahlgren Twp.	Community does not have a municipal system			
Dayton	0.4	0	0.002	1 - .002 SH
Deephaven	Served by Minnetonka (retail)			
Dellwood	Community does not have a municipal system			
Denmark Twp.	Community does not have a municipal system			
Douglas Twp.	Community does not have a municipal system			
Eagan	35.1	31.5	18.5	4 - 17 SE, 2 - 1.5 SU
East Bethel	0.7	0	0.002	2 - .002 SH
Eden Prairie	29.5	26.6	8.5	2 - 3 SE, 2 - 5.5 SU
Edina	25.2	23.7	7.0	4 - 3 SE, 1 - 4 SU
Elko New Market	1.8	1.1	0.4	2 - 0.4 SE
Empire Twp.	3.7	1.5	0.3	1 - 0.3 SE
Eureka Twp.	Community does not have a municipal system			
Excelsior	2.8	1.7	0.5	1 - 0.25 SE, 1 - 0.3 SU
Falcon Heights	Served by St. Paul Regional Water Services (retail)			
Farmington	10.3	7.4	2.1	1 - 1.5 SE, 1 - 0.67 SU

* Firm capacity is the well capacity of a community if the highest capacity well is out of service.

Fields left blank where information is not available.

Community	Total Capacity of Source (MGD)	Firm Capacity (MGD) *	Total Storage (MG)	Storage (MG)
Forest Lake	4.4	2.7	2.0	2 - 1 SE, 2 - 1 SU
Fridley	15.9	13.7	6.5	2 - 2 SE, 2 - 4.5 SU
Gem Lake	Community does not have a municipal system			
Golden Valley	Served by the Joint Water Commission			
Grant	Community does not have a municipal system			
Greenfield	0.6	0	0.25	1 - 0.25 SE
Greenvale Twp.	Community does not have a municipal system			
Greenwood	Served by Excelsior (retail)			
Grey Cloud Island Twp.	Community does not have a municipal system			
Ham Lake	Community does not have a municipal system			
Hamburg	5.4	3.3	0.05	1 - .05 SE
Hampton	1.9	0.8	0.075	1 - 0.075 SE
Hampton Twp.	Community does not have a municipal system			
Hancock Twp.	Community does not have a municipal system			
Hanover	Community does not have a municipal system			
Hassan Twp.	Community does not have a municipal system			
Hastings	9.4	7.8	2.7	2 - 1.75 SE, 1 - 1.0 SU
Helena Twp.	Community does not have a municipal system			

* Firm capacity is the well capacity of a community if the highest capacity well is out of service.

Fields left blank where information is not available.

Community	Total Capacity of Source (MGD)	Firm Capacity (MGD) *	Total Storage (MG)	Storage (MG)
Hilltop	Served by Minneapolis (wholesale)			
Hollywood Twp.	Community does not have a municipal system			
Hopkins	12.3	7.1	3.2	2 - 1 SE, 2 - 2.2 SU
Hugo	6.0	4.3	2.0	2 - 2.0 SE
Independence	Community does not have a municipal system			
Inver Grove Heights	10.0	8.3	8.7	2 - 3.0 SE, 3 - 8.5 SU
Jackson Twp.	Community does not have a municipal system			
Joint Water Commission	Served by Minneapolis (wholesale)		31.5	5 - 28.0 SE, 2 - 3.5.0 SU
Jordan	4.1	2.9	1.3	2 - 0.8 SE, 1 - 0.046 SU, 1 - 0.5 SS
Lake Elmo	2.1	0.72	0.085	1 - 0.075 SE, 1 - 0.010 SU
Lake St. Croix Beach	Served by Lakeland (retail)			
Lakeland	2.1	1.0	0.8	2 - 0.8 SU
Lakeland Shores	Served by Lakeland (retail)			
Laketown Twp.	Community does not have a municipal system			
Lakeville	28.6	26.3	8.8	5 - 5.75 SE, 2 - 3.10 SU
Landfall	Served by Oakdale (retail)			
Lauderdale	Served by St. Paul Regional Water Services (retail)			
Lexington				

* Firm capacity is the well capacity of a community if the highest capacity well is out of service.

Fields left blank where information is not available.

Community	Total Capacity of Source (MGD)	Firm Capacity (MGD) *	Total Storage (MG)	Storage (MG)
Lilydale	Served by St. Paul Regional Water Services (retail)			
Lino Lakes	6.5	4.3	2.0	2 - 2 SE
Linwood Twp.	Community does not have a municipal system			
Little Canada	Served by St. Paul Regional Water Services (wholesale)		1.5	1 - 1.5 SE
Long Lake	2.3	0.7	0.2	1 - 0.2 SE
Loretto	1.0	0.57	0.055	1 - 0.05 SE, 1 - 0.005 SU
Louisville Twp.	Community does not have a municipal system			
Mahtomedi	3.7	2.1	1.0	2 - 1 SE
Maple Grove	39.4	32.5	10.5	2 - 3.5 SE, 1 - 7.0 SU, 1 - 2.0 Clearwell
Maple Plain	1.8	0.8	0.4	1 - 0.4 SE, 1 - 0.095 Clearwell
Maplewood	Served by St. Paul Regional Water Services (retail)			
Marine on St. Croix	Community does not have a municipal system			
Marshan Twp.	Community does not have a municipal system			
May Twp.	Community does not have a municipal system			
Mayer	0.9	0.5	0.4	1 - 0.4 SE
Medicine Lake	Community does not have a municipal system			
Medina	2.5	1.4	0.4	1 - 0.4 SE, 1 - 0.2 Clearwell
Mendota	Served by St. Paul Regional Water Services (retail)			

* Firm capacity is the well capacity of a community if the highest capacity well is out of service.

Fields left blank where information is not available.

Community	Total Capacity of Source (MGD)	Firm Capacity (MGD) *	Total Storage (MG)	Storage (MG)
Mendota Heights	Served by St. Paul Regional Water Services (retail)			
Miesville	Community does not have a municipal system			
Minneapolis Water Works	219.0	189	124.2	9 - 199.2 SU
Minnetonka	31.2	28.5	12.8	6 - 4.8 SE, 2 - 8 SU
Minnetonka Beach	0.7	0.3	0.1	1 - 0.05 SE, 1 - 0.075 SU
Minnetrista	2.7	0.7	0.7	2 - 0.7 SE
Mound	3.6	1.5	0.9	2 - 0.7 SE, 1 - 0.265 SU
Mounds View	7.2	5.7	2.5	1 - 0.5 SE, 1 - 2.0 SU
New Brighton	11.4	9.9	2.7	3 - 1.45 SE, 1 - 1.3 SU
New Germany	0.1	0	0.05	1 - 0.05 SE, 1 - 0.075 SU
New Hope	Served by the Joint Water Commission			
New Market Twp.	Community does not have a municipal system			
New Trier				
Newport	3.0	1.2	0.7	2 - 0.75 SU
Nininger Twp.	Community does not have a municipal system			
North Oaks	Served by White Bear Twp (retail)			
North St. Paul	7.9	5.9	0.8	2 - 0.8 SE
Norwood Young America	2.0	1.5	0.5	2 - 0.5 SE

* Firm capacity is the well capacity of a community if the highest capacity well is out of service.

Fields left blank where information is not available.

Community	Total Capacity of Source (MGD)	Firm Capacity (MGD) *	Total Storage (MG)	Storage (MG)
Nowthen	Community does not have a municipal system			
Oak Grove	1.0	0.8	0.04	1 - 1.0 SE (St. Francis), 1 - .04 SU
Oak Park Heights	2.4	1.2	0.75	1 - .75 SE
Oakdale	12.8	10.5	3.9	4 - 3.9 SE
Orono	2.8	1.4	0.65	2 - 0.65 SE
Osseo	Served by Maple Grove (wholesale)			
Pine Springs	Community does not have a municipal system			
Plymouth	38.4	35.5	13.5	5 - 7.5 SE, 1 - 6 SU
Prior Lake	6.7	5	1.75	2 - 1.75 SE
Ramsey	11.7	9.1	2.0	2 - 2.0 SE
Randolph				
Randolph Twp.	Community does not have a municipal system			
Ravenna Twp.	Community does not have a municipal system			
Richfield	19.5	16.3	5.0	2 - 2.5 SE, 1 - 2.5 (clearwell) SU
Robbinsdale	2.8	0	1.85	2 - 0.6 SE, 2 - 1.25 SU
Rogers	6.6	5.18	1.2	2 - 1.15 SE
Rosemount	10.9	8.7	3.5	4 - 3.5 SE
Roseville	Served by St. Paul Regional Water Services (wholesale)		1.5	1 - 1.5 SE

* Firm capacity is the well capacity of a community if the highest capacity well is out of service.

Fields left blank where information is not available.

Community	Total Capacity of Source (MGD)	Firm Capacity (MGD) *	Total Storage (MG)	Storage (MG)
San Francisco Twp.	Community does not have a municipal system			
Sand Creek Twp.	Community does not have a municipal system			
Savage	10.4	8.2	9.0	3 - 2.5 SE, 2 - 6.5
Scandia	Community does not have a municipal system			
Sciota Twp.	Community does not have a municipal system			
Shakopee Public Utilities	22.3	17.3	9.25	4 - 4.25 SE, 2 - 5 SU
Shoreview	12.9	10.4	4.0	2 - 1.5 SE, 1 - 1 SU
Shorewood	5.6	4.1	0.919	2 - 0.9 SE, 2 - 0.019 SU
South St. Paul	14.5	11.5	3.15	2 - 1.15 SE, 2 - 2 SU
Spring Lake Park	6.3	4.2	0.25/0.5	2 - 0.25/0.5 SE
Spring Lake Twp.	Community does not have a municipal system			
Spring Park	1.7	0.8	0.3	1 - 0.2 SE, 1 - 0.1 SU
St. Anthony	5.1	3.4	2.3	1 - 0.25 SE, 1 - 2 SU
St. Bonifacius	1.1	0.4	0.3	1 - 3 0.3 SE
St. Francis	4.7	3.4	1.95	1 - 0.75 SE, 1 - 1.2 SU (clearwell)
St. Lawrence Twp.	Community does not have a municipal system			
St. Louis Park	15.1	13.32	9.5	3 - 3 SE, 4 - 5.5 SU,
St. Marys Point	Community does not have a municipal system			

* Firm capacity is the well capacity of a community if the highest capacity well is out of service.

Fields left blank where information is not available.

Community	Total Capacity of Source (MGD)	Firm Capacity (MGD) *	Total Storage (MG)	Storage (MG)
St. Paul Regional Water Services	N/A	N/A	131.3	14 - 21.3 SE, 7 - 110 SU
St. Paul Park	3.4	2.1	1.25	2 - 1.25 SE
Stillwater	9.9	7.7	3.25	1 - 0.5 SE, 2 - 2 SU, 1 - 0.75 Standpipe
Stillwater Twp.	Community does not have a municipal system			
Sunfish Lake	Community does not have a municipal system			
Tonka Bay	2.2	1	0.565	1 - 0.25 SE, 1 - 0.3 SU, 1 - 0.015 SH
Vadnais Heights				
Vermillion	0.8	0.4	0.55	1 - 0.55 SE
Vermillion Twp.	Community does not have a municipal system			
Victoria	4.8	3	1.1	1 - 0.5 SE, 1 - 0.612 SU
Waconia	5.5	3.4	2.975	3 - 2.325 SE, 1 - 0.65 SU
Waconia Twp.	Community does not have a municipal system			
Waterford Twp.	Community does not have a municipal system			
Watertown	2.0	1.0	0.4	1 - 0.3 SE, 1 - 0.1 SU
Watertown Twp.	Community does not have a municipal system			
Wayzata	4.7	3.0	0.5	1 - 0.5 SE
West Lakeland Twp.	Community does not have a municipal system			
West St. Paul	Served by St. Paul Regional Water Services (retail)			

* Firm capacity is the well capacity of a community if the highest capacity well is out of service.

Fields left blank where information is not available.

Community	Total Capacity of Source (MGD)	Firm Capacity (MGD) *	Total Storage (MG)	Storage (MG)
White Bear Lake	11.1	7.4	5.0	1 - 1 SE, 1 - 3 SU, 1 - 1 clearwell
White Bear Twp.	8.8	6.4	1.85	3 - 1.85 SE
Willernie	Served by Mahtomedi (wholesale)			
Woodbury	29.7	26.8	10.5	1 - 0.5 SE, 2 - 4 SU
Woodland	Served by Minnetonka (retail)			
Young America Twp.	Community does not have a municipal system			

* Firm capacity is the well capacity of a community if the highest capacity well is out of service.

Fields left blank where information is not available.